NON-CONTROLLED COPY	COPY ISSUED BY_____.
INFORMATION SUBJECT TO CHANGE WITHOUT NOTICE	
COPY WILL NOT BE UPDATED	COPY ISSUED ON_____.



NOZZLE SCHEDULE & ACCESSORIES

SERVICE	MK	STOCK NO.	SIZE	FITTING	DEG	ELEV



NOTE: A
MUST USE FLEXIBLE CONNECTIONS ALL LOWER SIDEWALL FITTINGS

NOTES
1. THIS IS A COMPUTER GENERATED DWG. DO NOT REVISE BY HAND.
2. DIMENSIONS WILL VARY ±3% DUE TO VARIATIONS IN MULTIPLE MOLDS & CONDITIONS PREVALENT DURING MANUFACTURE & USAGE.
3. 5 1/2" WIDE MOLDED IN GALLONAGE MARKERS ON SIDEWALL IN 200 GALLON INCREMENTS STARTING AT 100 GALLON UP TO 1500 GALLON. AVOID WHEN PLACING FITTINGS.

CALCULATED CAPACITY VOLUME IN U.S. GALLONS
DESIGN CAPACITY
2046

CONFIDENTIAL PROPERTY OF POLY PROCESSING COMPANY NOT FOR REPRINT OR USE WITHOUT PERMISSION

DWG TITLE: 2000 GALLON OPEN TOP TANK W/COVER

SCALE: 1/2"=1'-0"
DATE: 12/28/99

POLY PROCESSING Company
Central Region
P.O. Box 4150 (71211)
2201 Old Sterlington Rd.
Monroe, LA 71203
(318) 343-7565
FAX (318) 343-8795

DR: MB WILKERSON
CK: J. BRANTLEY

SHEET: 1 OF 1
COMPUTER FILE: 1502000C
REV: A

REV "A" ADDED FITTING NOTE BY:MBW 4/14/03 CK:JB

B-5