NON-CONTROLLED COPY

INFORMATION SUBJECT TO CHANGE WITHOUT NOTICE

VERIFY REV LEVEL OF PAPER COPY WITH REV LEVEL ON PPC WEB SITE



NOZZLE SCHEDULE & ACCESSORIES

SERVICE	MK	STOCK NO.	SIZE	FITTING	DEG	ELEV



LUG DETAIL "A"
SCALE: 1 1/2" = 1'-0"



NOTE:
MUST USE FLEXIBLE CONNECTIONS ALL LOWER SIDEWALL FITTINGS

NOTES:
1. THIS IS A COMPUTER GENERATED DWG. DO NOT REVISE BY HAND.
2. DIMENSIONS WILL VARY ±3% DUE TO VARIATIONS IN MULTIPLE MOLDS & CONDITIONS PREVALENT DURING MANUFACTURE & USAGE.
3. GALLONAGE MARKERS ON SIDE WALL IN 200 GAL INCREMENTS UP TO 5600 GALLON.
4. FOR INNER TANK DTLS SEE COMPUTER FILE NO. 2006650, TITLE "6650 GALLON INNER SAFE-TANK." FOR ASSEMBLY DTLS SEE COMPUTER FILE NO. 2006650A, TITLE "6650 GALLON SAFE-TANK ASSEMBLY."

CALCULATED CAPACITY VOLUME IN U.S. GALLONS
DESIGN CAPACITY
7455

CONFIDENTIAL PROPERTY OF POLY PROCESSING COMPANY NOT FOR REPRINT OR USE WITHOUT PERMISSION

DWG TITLE: 6650 GALLON OUTER SAFE-TANK/ 7450 GALLON OPEN TOP TANK

SCALE: 1/4"-1'-0"

DATE: 9/15/03

POLYPROCESSING COMPANY
Western Region
P.O. Box 4150 (71211)
2201 Old Sterlington Rd.
Monroe, LA 71203
(318) 343-7565
FAX (318) 343-8795

DR: MB WILKERSON

CK: J. BRANTLEY

SHEET	COMPUTER FILE	REV
1 OF 1	12107450	A

REV "A" MOLD MOD. DELETED CHOCKS BY:MBW 11/12/07 CK:JB

B-25