NON-CONTROLLED COPY INFORMATION SUBJECT TO CHANGE WITHOUT NOTICE

COPY WILL NOT BE UPDATED

COPY ISSUED BY_____.

NOZZLE SCHEDULE & ACCESSORIES SERVICE | MK STOCK NO. SIZE FITTING DEG ELEV 270° 215* 325* 6 LIFTING LUGS LOCATED @ 35*, 90*, 145*, 215*, 270°, 325° 4 3/4" 180° 145* 1 1/2"ø 90* LUG DETAIL "A" SCALE: 1 1/2" = 1'-0" THIS IS A COMPUTER GENERATED DWG. DO NOT REVISE BY HAND. 2. DIMENSIONS WILL VARY ±3% DUE TO VARIATIONS IN MULTIPLE MOLDS & CONDITIONS PREVALENT DURING MANUFACTURE & USAGE. SEE DTL "A" 3. NO MOLDED IN GALLONAGE MARKERS THIS TANK. 4. FOR INNER TANK DTLS SEE COMPUTER FILE NO. 12004400, TITLE "4400 GALLON INNER SAFE-TANK." FOR ASSEMBLY DTLS SEE COMPUTER FILE NO. 12004400A, TITLE, "4400 GALLON SAFE-TANK ASSEMBLY." CHOCK ONLY CALCULATED CAPACITY NOT TO BE USED FOR CONFIDENTIAL PROPERTY OF V□LUME IN U.S. GALL□NS FITTING LOCATION POLY PROCESSING COMPANY DESIGN CAPACITY (4) PL (35°, 145°, NOT FOR REPRINT OR USE 215°, 325°) 4994 WITHOUT PERMISSION DWG TITLE 4400 GALLON OUTER SAFE-TANK/ NOTE: MUST USE FLEXIBLE 4950 GALLON OPEN TOP TANK CONNECTIONS ALL **POLY** Western Region P.I. Box 80 9055 South Ash Street French Canp, CA 95231 (299) 982-4904 FAX (209) 982-0455 MB WILKERSON SCALE: 3/8"=1'-0" **LOWER SIDEWALL** PROCESSING **FITTINGS** DATE 10'-2 1/2" DD 8/6/02 J. BRANTLEY SHEET COMPUTER FILE 1 DF 1 12104950 REV "A" ADDED FITTING NOTE BY:MBW 4/16/03 CK:JB