


ELEVATIONS ONLY--
NOZZLES & ACCESSORIES
ROTATED INTO VIEW--
FOR TRUE ORIENTATION
SEE PLAN VIEW




NOTE:
MUST USE FLEXIBLE
CONNECTIONS ALL
LOWER SIDEWALL
FITTINGS

| CALCULATED CAPACITIES/ VOLUME IN U.S. GALLONS | | | |
|--|------------|----------|-----------|
| TANK | DESIGN CAP | DOME VOL | TOTAL VOL |
| INNER | 750 | 56 | 806 |
| OUTER | 944 | N/A | 944 |

NOTES:

1. THIS IS A COMPUTER GENERATED DWG. DO NOT REVISE BY HAND.
2. DIMENSIONS WILL VARY $\pm 3\%$ DUE TO VARIATIONS IN MULTIPLE MOLDS & CONDITIONS PREVALENT DURING MANUFACTURE & USAGE.
3. INNER TANK DESIGNED FOR 1.9 SpG MAT'L @ 100°F/ATMOS PRESSURE
OUTER TANK DESIGNED FOR 1.9 SpG MAT'L @ 100°F/ATMOS PRESSURE

| | | | |
|-------------------|---|--|------------|
| DWG TITLE | | 750 GALLON SAFE-TANK ASSEMBLY | |
| SERVICE: XXXXX | | INNER: 1.9 SpG/XLPE/NATURAL STOCK NO. XXXXXX OUTER: 1.9 SpG/XLPE/NATURAL STOCK NO. XXXXXX | |
| SCALE: 1/2"=1'-0" |  | Central Region P.O. Box 4199 712110 2201 Old Sterlington Rd. Harrison, LA 71223 C318D 343-7365 FAX C318D 343-8795 | DR: XXXXXX |
| DATE: XXXX | | CK: XXXXXX | |
| SHEET 1 OF 1 | | COMPUTER FILE | REV - |