NON-CONTROLLED COPY

INFORMATION SUBJECT TO CHANGE WITHOUT NOTICE

VERIFY REV LEVEL OF PAPER COPY WITH REV LEVEL ON PPC WEB SITE







LIFTING LUG DETAIL
(3) PLACES
SCALE: 1"=1'-0"




RUNWAY DETAIL
(2) PLACES

| NOZZLE SCHEDULE & ACCESSORIES | | | | | | |
|---|---|---|---|---|---|---|
| SERVICE | MK | STOCK NO. | SIZE | FITTING | DEG | ELEV |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |




IMFD STUB DETAIL
SCALE: 3/4"=1'-0"




**NOTE:**
**MUST USE FLEXIBLE CONNECTIONS ALL LOWER SIDEWALL FITTINGS**

NOTES
1. THIS IS A COMPUTER GENERATED DWG. DO NOT REVISE BY HAND.
2. DIMENSIONS WILL VARY ±3% DUE TO VARIATIONS IN MULTIPLE MOLDS & CONDITIONS PREVALENT DURING MANUFACTURE & USAGE.
3. MOLDED IN GALLONAGE MARKERS @ APPROX 60° IN 200 GAL INCREMENTS UP TO 2200 GAL.
   GALLONAGE MARKERS ARE 5" WIDE AND MUST BE AVOIDED WHEN PLACING FITTINGS.

| CALCULATED CAPACITIES/ VOLUME IN U.S. GALLONS | | |
|---|---|---|
| DESIGN CAP | DOME VOL | TOTAL VOL |
| 2559 | 142 | 2701 |

CONFIDENTIAL PROPERTY OF POLY PROCESSING COMPANY
NOT FOR REPRINT OR USE WITHOUT PERMISSION

DWG TITLE: 2550 GALLON UPRIGHT TANK (VA)

SCALE: 3/8"=1'-0"

DATE: 8/12/09

POLYPROCESSING SOLUTIONS, SIMPLIFIED.
Central Region
P.O. Box 4150 (71211)
2201 Old Sterlington Rd.
Monroe, LA 71203
(318) 343-7565
FAX (318) 343-8795

DR: J. BRANTLEY

CK: W. MANUEL

| SHEET | COMPUTER FILE | REV |
|---|---|---|
| 1 OF 1 | 1002550V | A |

REV "A" CORRECTED KNUCKLE RADIUS BY:JB 2/8/19

B-378